

Compliance Document for New Zealand Building Code Clause G5 Interior Environment

Prepared by the Department of Building and Housing

This Compliance Document is prepared by the Department of Building and Housing. The Department of Building and Housing is a Government Department established under the State Sector Act 1988.

Enquiries about the content of this document should be directed to:



Department of
Building and Housing

Te Tari Kaupapa Whare

Department of Building and Housing
PO Box 10-729, Wellington.
Telephone 0800 242 243
Fax 04 494 0290
Email: info@dbh.govt.nz



Sales enquiries should be directed to:
Customer Services,
Victoria University Book Centre
PO Box 12-337, Wellington, New Zealand
Telephone 0800 370 370, (04) 463 5511
Fax (04) 463 5510
Email: dbh@vicbooks.co.nz
www.vicbooks.co.nz
ISBN 0-477-01606-5

© Department of Building and Housing 2006

This Compliance Document is protected by Crown copyright, unless indicated otherwise. The Department of Building and Housing administers the copyright in this document. You may use and reproduce this document for your personal use or for the purposes of your business provided you reproduce the document accurately and not in an inappropriate or misleading context. You may not distribute this document to others or reproduce it for sale or profit.

The Department of Building and Housing owns or has licences to use all images and trademarks in this document. You must not use or reproduce images and trademarks featured in this document for any purpose (except as part of an accurate reproduction of this document) unless you first obtain the written permission of the Department of Building and Housing.

Status of Compliance Documents

Compliance Documents are prepared by the Department of Building and Housing in accordance with section 22 of the Building Act 2004. A Compliance Document is for use in establishing compliance with the New Zealand Building Code.

A person who complies with a Compliance Document will be treated as having complied with the provisions of the Building Code to which the Compliance Document relates. However, a Compliance Document is only one method of complying with the Building Code. There may be alternative ways to comply.

Users should make themselves familiar with the preface to the New Zealand Building Code Handbook, which describes the status of Compliance Documents and explains alternative methods of achieving compliance.

Defined words (italicised in the text) and classified uses are explained in Clauses A1 of the Building Code and in the Definitions at the start of this Compliance Document.

| G5: Document History | | |
|---|-------------|---|
| | Date | Alterations |
| First published | July 1992 | |
| Amendment 1 | 1 July 2001 | p. 2, Document History, Status p. 3, NZBC p. 7, References p. 9, Definitions |
| Note: Page numbers relate to the document at the time of Amendment and may not match page numbers in current document. | | |

Document Status

The most recent version of this document, as detailed in the Document History, is approved by the Chief Executive of the Department of Building and Housing. It is effective from 1 July 2001 and supersedes all previous versions of this document.

People using this Compliance Document should check for amendments on a regular basis. The Department of Building and Housing may amend any part of any Compliance Document at any time. Up-to-date versions of Compliance Documents are available from www.dbh.govt.nz

New Zealand Building Code

Clause G5 Interior Environment

Amend 1
Jul 2001

The mandatory provisions for building work are contained in the New Zealand Building Code (NZBC), which comprises the First Schedule to the Building Regulations 1992. The relevant NZBC Clause for Interior Environment is G5. Note that section 25 of the Disabled Persons Community Welfare Act 1975 has been replaced by section 47A of the Building Act 1991.

| FIRST SCHEDULE—continued | |
|--|---|
| Clause G5—INTERIOR ENVIRONMENT | |
| Provisions | Limits on application |
| <p>OBJECTIVE</p> <p>G5.1 The objective of this provision is to:</p> <ul style="list-style-type: none"> (a) Safeguard people from illness caused by low air temperature, (b) Safeguard people from injury or loss of <i>amenity</i> caused by inadequate activity space, (c) Safeguard people from injury caused by unsafe installations, and (d) Ensure that <i>people with disabilities</i> are able to carry out normal activities and processes within <i>buildings</i>. <p>FUNCTIONAL REQUIREMENT</p> <p>G5.2.1 <i>Buildings</i> shall be <i>constructed</i> to provide:</p> <ul style="list-style-type: none"> (a) An <i>adequate</i>, controlled interior temperature, (b) <i>Adequate</i> activity space for the <i>intended use</i>, and (c) <i>Accessible</i> spaces and facilities. <p>G5.2.2 Heating appliances in <i>buildings</i> shall be installed in a way that reduces the likelihood of injury.</p> <p>PERFORMANCE</p> <p>G5.3.1 <i>Habitable spaces</i>, bathrooms and recreation rooms shall have the provision for maintaining the internal temperature at no less than 16°C measured at 750 mm above floor level, while the space is <i>adequately</i> ventilated.</p> | <p>Objective G5.1 (d) shall apply to those <i>buildings</i> to which section 25 of the Disabled Persons Community Welfare Act 1975 applies.</p> <p>Requirement G5.2.1 (a) shall apply only to <i>habitable spaces</i>, bathrooms and recreation rooms in old people’s homes and early childhood centres.</p> <p>Requirement G5.2.1 (b) shall apply only to old people’s homes.</p> <p>Requirement G5.2.1 (c) shall apply only to <i>Communal Residential</i>, <i>Communal Non-residential</i>, and <i>Commercial buildings</i>.</p> <p>Performance G5.3.1 shall apply only to old people’s homes and early childhood centres.</p> |

FIRST SCHEDULE—continued

Provisions

G5.3.2 Heating appliances, and any attached cables, pipes or other fittings shall be securely fixed in place.

G5.3.3 *Habitable spaces* shall have sufficient space for activity, furniture, and sanitary and mobility aids.

G5.3.4 Where reception counters or desks are provided for public use, at least one counter or desk shall be *accessible*.

G5.3.5 *Buildings* shall be provided with listening systems which enable enhanced hearing by people with hearing aids.

G5.3.6 Enhanced listening systems shall be identified by signs complying the Clause F8 “Signs”.

Limits on application

Performance G5.3.2 shall apply only to old people’s homes and early childhood centres.

Performance G5.3.3 shall apply only to old people’s homes.

Performance G5.3.4 applies only to *Communal Residential, Communal Non-Residential, and Commercial buildings*.

Performance G5.3.5 applies only to:

- (a) *Communal Non-residential* assembly spaces occupied by more than 250 people, and
- (b) Any theatre, cinema, or public hall, and
- (c) Assembly spaces in old people’s homes occupied by more than 20 people.

Contents

| | Page |
|-------------------------------------|-------------|
| References | 7 |
| Definitions | 9 |
| Verification Method G5/VM1 | 11 |
| Acceptable Solution G5/AS1 | 13 |
| 1.0 Temperature Control | 13 |
| 2.0 Space | 14 |
| 3.0 People with Disabilities | 14 |
| Index | 15 |

References

Amend 1
Jul 2001

For the purposes of New Zealand Building Code compliance, acceptable reference documents include only the quoted edition and specific amendments as listed below.

Standards Association of New Zealand

Amend 1
Jul 2001

| | |
|----------------|---|
| NZS 4121: 2001 | Design for access and mobility – Buildings and associated facilities |
| NZS 4214: 1977 | Methods of determining the total thermal resistance of parts of buildings |

Where quoted

AS1 3.0.1

Definitions

Definitions

This is an abbreviated list of definitions for words or terms particularly relevant to this Approved Document. The definitions for any other italicised words may be found in the New Zealand Building Code Handbook.

- Accessible** Having features to permit use by *people with disabilities*.
- Adequate** *Adequate* to achieve the objectives of the *building code*.
- Amenity** An attribute of a *building* which contributes to the health, physical independence, and well being of the *building's* users but which is not associated with disease or a specific illness.
- Building** has the meaning ascribed to it by the Building Act 1991.
- Building element** Any structural and non-structural component or assembly incorporated into or associated with a *building*. Included are *fixtures*, services, drains, permanent mechanical installations for access, glazing, partitions, ceilings and temporary supports.
- Fixture** An article intended to remain permanently attached to and form part of a *building*.
- Habitable space** A space used for activities normally associated with domestic living, but excludes any bathroom, laundry, water-closet, pantry, walk-in wardrobe, corridor, hallway, lobby, clothes-drying room, or other space of a specialised nature occupied neither frequently nor for extended periods.
- Intended use** of a *building* includes:
- Any reasonably foreseeable occasional other use that is not incompatible with the *intended use*; and
 - Normal maintenance; and
 - Activities taken in response to *fire* or any other reasonably foreseeable emergency – but does not include any other maintenance and repairs or rebuilding.

People with disabilities means any *person* who suffers from physical or mental disability to such a degree that he or she is seriously limited in the extent to which he or she can engage in the activities, pursuits, and the processes of everyday life.

Amend 1
Jul 2001

R-value The common abbreviation for describing the values of both *thermal resistance* and *total thermal resistance*.

Thermal resistance The resistance to heat flow of a given component of a *building element*. It is equal to the temperature difference (°C) needed to produce unit heat flux (W/m²) through unit area (m²) under steady conditions. The units are °Cm²/W.

Total thermal resistance The overall air-to-air *thermal resistance* across all components of a *building element* such as a wall, roof or floor. (This includes the surface resistances which may vary with environmental changes e.g. temperature and humidity, but for most purposes can be regarded as having standard values as given in NZS 4214.)

Verification Method G5/VM1

No specific methods have been adopted for verifying compliance with the Performance of NZBC G5.

Acceptable Solution G5/AS1

1.0 Temperature Control

1.0.1 Heating to provide acceptable temperature control shall take account of:

- a) Local climate,
- b) Size of the heated space,
- c) *Thermal resistance (R-value)* of the *building elements* enclosing the space to be heated, and
- d) Whether the walls of the heated space are internal or external.

1.0.2 Indicative *R-values* for different types of *construction* are given in E3/AS1.

1.0.3 Tables 1 and 2 provide a method of determining the heating requirements for the *habitable spaces*, bathrooms and recreation rooms of smaller old people's homes and early childhood centres (up to 10 residents), of single storey *construction*. The heating requirements of larger and multi-storey *buildings* shall be specifically calculated.

Table 1: Acceptable Heating Output for Spaces of up to 10 m² Floor Area (See note 1)
Paragraph 1.0.3

| Locality | Average R-value <small>(the average total thermal resistance of floor, walls and roof/ceiling of the space to be heated)</small> | Heating wattage (W) for a space which has | | | |
|--------------|---|---|----------------------|--------------------|-------------------|
| | | Four external walls | Three external walls | Two external walls | One external wall |
| North Island | 1.5 | 720 | 650 | 580 | 510 |
| (see note 2) | 0.7 | 1250 | 1100 | 950 | 800 |
| South Island | 1.5 | 1040 | 940 | 840 | 740 |
| | 0.7 | 1650 | 1410 | 1170 | 930 |

Notes:

- For floor areas exceeding 10 m² use factors given in Table 2.
- North Island localities more than 500 m above sea level shall meet South Island requirements.

Table 2: Multiplying Factors for Determining Acceptable Wattage in Spaces Exceeding 10 m² Floor Area
Paragraph 1.0.3 and Table 1

| | | | | | |
|------------------------------|-----|-----|-----|-----|-----|
| Floor area (m ²) | 10 | 20 | 40 | 80 | 160 |
| Multiplying factor | 1.0 | 1.4 | 2.0 | 2.8 | 4.0 |

Note:
Interpolation for different floor areas is permitted.

1.0.4 Example of use of Tables 1 and 2:

For a space (South Island) of 20 m² and an average *R-value* of 1.5, with 2 external walls, the necessary heating power is:

$$840 \text{ (Table 1)} \times 1.4 \text{ (Table 2)} = 1176 \text{ W}$$

The average *R-value* for example may be

$$\frac{0.4 \text{ (floor)} + 2.0 \text{ (walls)} + 3.0 \text{ (roof)}}{3} = \frac{5.4}{3} = 1.8$$

In this case the wattage is read from the 1.5 Average *R-value* line, in Table 1.

2.0 Space

2.0.1 Each old people’s home shall have spaces for living, dining and sleeping.

2.0.2 Spaces for living and dining may be combined provided that the total space can, if necessary, be divided into separate living and dining areas each satisfying their respective requirements for width and floor area.

2.0.3 Spaces provided shall have dimensions of no less than those given in Table 3.

3.0 People with Disabilities

3.0.1 Acceptable activity space shall comply with NZS 4121.

Table 3: Space Provision for Old People’s Homes
Paragraph 2.0.3

| Type of space | Minimum dimensions | |
|---------------|--------------------|---|
| | Width (m) | Floor area (m ²) |
| Living room | 2.75 | 10 + 1 for each resident over 3 in number |
| Dining room | 2.75 | 8 + 1 for each resident over 3 in number |
| Bedroom | 2.2 | 6 for each resident (see note 1) |

Note:
1. Floor area for bedrooms shall exclude built-in wardrobes. In the absence of a built-in wardrobe, an additional 0.75 m² shall be provided for each resident.

Index G5/VM1 & AS1

All references to Verification Methods and Acceptable Solutions are preceded by **VM** or **AS** respectively.

| | |
|---------------------------------------|--------------------------------|
| Early childhood centres | AS1 1.0.3 |
| Old people's homes | AS1 1.0.3, 2.0, Table 3 |
| People with disabilities | AS1 3.0 |
| Space requirements | AS1 2.0, Table 3 |
| Temperature control | AS1 1.0, Tables 1 and 2 |

